



CITY OF DECATUR ILLINOIS

#1 GARY K. ANDERSON PLAZA

DECATUR, ILLINOIS 62523-1196

April 20, 2022

Re: Notice of PFAS Sample Results

Dear City of Decatur Water Customer,

The Illinois Environmental Protection Agency (Illinois EPA) recently tested the City’s water system for 18 compounds known as Per- and Polyfluoroalkyl Substances (PFAS) as part of a statewide investigation of community water supplies. PFAS are a group of thousands of manmade substances that have been produced in the United States since the 1940s and utilized for a variety of applications ranging from water and stain-proofing to firefighting. Some PFAS have been phased out of production in the United States due to environmental and human health concerns, yet they persist in the environment and may be found in surface and ground waters.

Neither the Illinois EPA nor the U.S. EPA have yet developed enforceable drinking water standards for PFAS. In the interim, Illinois EPA has developed health-based guidance levels for the small number of PFAS for which there is appropriate information to do so. The health-based guidance levels are intended to be protective of all people consuming the water over a lifetime of exposure.

While none of the compounds sampled were above the health-based guidance levels, Illinois EPA testing has determined that one PFAS compound was detected in our water system at levels greater than or equal to the lowest concentration the laboratory can reliably detect, shown as the Minimum Reporting Level in the table below. The levels are presented in units of nanogram per liter (ng/L) or parts per trillion (ppt). ND indicates that the compound was Non-Detectable (undetected).

PFAS Compound	Acronym	Minimum Reporting Level (ng/L)	Health-Based Guidance Level (ng/L)	Analytical Result (ng/L) 12/17/2020	Analytical Result (ng/L) 1/19/2021
Perfluorobutanesulfonic acid	PFBS	2	2,100	ND	ND
Perfluoroheptanoic acid	PFHpA	2	---	ND	ND
Perfluorohexanesulfonic acid	PFHxS	2	140	ND	ND
Perfluorononanoic acid	PFNA	2	21	ND	ND
Perfluorooctanesulfonic acid	PFOS	2	14	ND	ND
Perfluorooctanoic acid	PFOA	2	2	ND	ND
Perfluorodecanoic acid	PFDA	2	---	ND	ND
Perfluorododecanoic acid	PFDoA	2	---	ND	ND
Perfluorohexanoic acid	PFHxA	2	560,000	2.4	2.6
Perfluorotetradecanoic acid	PFTA	2	---	ND	ND
Perfluorotridecanoic acid	PFTTrDA	2	---	ND	ND
Perfluoroundecanoic acid	PFUnA	2	---	ND	ND
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	2	---	ND	ND
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9Cl-PF3ONS	2	---	ND	ND
4,8-dioxa-3H-perfluorononanoic acid	ADONA	2	---	ND	ND

Hexafluoropropylene oxide dimer acid	HFPO-DA	2	560	ND	ND
N-ethyl perfluorooctanesulfonamidoacetic acid	NEtFOSAA	2	---	ND	ND
N-methyl perfluorooctanesulfonamidoacetic acid	NMeFOSAA	2	---	ND	ND

*Toxicity criteria is not available to calculate a health-based guidance level.

Only one PFAS compound, Perfluorohexanoic acid (PFHxA) was detected in the City’s water system. The detection level was 2.4 ngL and 2.6 ngL which is significantly below the Health-Based Guidance Level of 560,000 ngL.

PFAS are present in many consumer goods, including food packaging and personal care products, and scientists have found levels of PFAS in the blood of nearly all individuals tested. Exposure to high levels of PFAS over time may cause adverse health effects such as increased cholesterol levels, increased risk of thyroid disease, low infant birth weight, reduced response to vaccines, pregnancy-induced hypertension and increased risk of liver and kidney cancer as seen in studies of laboratory animals. Exposure to PFAS above the recommended health-based guidance levels does not mean that a person will get sick or an adverse health effect will occur. Health-based guidance levels are conservative estimates. The possible health effects of PFAS are dependent on how much a person is exposed to and how they are exposed to it. Exposure to PFAS above recommended health-based guidance levels for periods of time may mean that a person is at a greater risk of experiencing these adverse effects.

In response to the results of this testing, the City of Decatur has done the following:

1. Generated this Public Notice Letter to inform water consumers about PFAS Testing and Sampling results.
2. Created a PFAS Public Education document to be available on the City of Decatur’s website or to pick up by request.
3. Completed one full year of quarterly PFAS sampling resulting in non-detectable limits for all PFAS tested.
4. Annually sample and review PFAS results to determine appropriate steps to reduce public exposure.

Additional information regarding PFAS, the statewide PFAS investigation network and the impact to public health can be found in the attached fact sheet as well as on the Illinois EPA PFAS webpage:

<https://www2.illinois.gov/epa/topics/water-quality/pfas/Pages/default.aspx>.

The confirmed sampling results for the City of Decatur are also available on Illinois EPA’s Drinking Water Watch system at <http://water.epa.state.il.us/dww/index.jsp>.

This document can be found on the City’s website at: <https://decaturil.gov/2022-PFAS-Notification>

If you have questions, please contact:

City of Decatur
 Chaundra Smith, Water Production Operations Supervisor
csmith@decaturil.gov
 217/424-2833

Illinois Environmental Protection Agency
 Barb Lieberoff, Office of Community Relations
epa.pfas@illinois.gov
 217-524-3038

Illinois Department of Public Health
 Brian Koch, Division of Environmental Health
Brian.Koch@illinois.gov
 217-782-5830