

Project HVAC IFB #Transit 2022-06

ADDENDUM #5

Clarification, the AHU Cooling Coil at Decatur Mass Transit is to remain. If we find that the coil will not handle the pressures of the new refrigerant, then replacement of the coil will be handled through a change order.

Thank you,

Jessica Taylor

Procurement & Transit Grant Manager

555 E. Wood St.

Decatur, IL 62523